

**Bid Summary Document**

<b>Bid Details</b>	
Bid Status	<b>Closed</b>
Bid Owner Department	Department of Defence
Creation Date	06-01-2018 08:18
Bid Start Date / Time	06-01-2018 08:18
Bid End Date / Time	13-01-2018 08:16
Product Quantity	1
<b>Product Details</b>	
Product Category	reverse osmosis water purifier-RO
Product Specifications	<b>Conformity to Indian Standard for System - IS:14724( latest)</b>
	<b>Output Water of RO system Conforming to Indian Standard - IS:10500( latest)</b>
	<b>Input water TDS - 2000 mg/L</b>
	<b>Output Capacity - 250 L/Hrs</b>
	<b>Recovery at 27 °C - 25-35 %</b>
	<b>Thin-film composite membrane. - Yes</b>
	<b>Ultraviolet (UV) LAMP - Yes</b>
	<b>Ultraviolet (UV)LAMP Wattage - 11</b>
	<b>Number of float valves/sensors - 1</b>
	<b>High Pressure Pump - Yes</b>
	<b>Raw water/Chemical Raw water/Chemical Cleaning PUMP: - No</b>
	<b>Pre Filter Vessels: - Yes</b>
	<b>Micron Filter: - Yes</b>
	<b>Membrane Housing: - Yes</b>
	<b>Auto cut: - Yes</b>
	<b>No of candles - 5 Nos</b>

	<b>Installation Type - Table Top</b>
	<b>Warranty for free candle and activated carbon replacement twice a year - 2 Years</b>
	<b>Warranty for free replacement of machine - 2 Years</b>
	<b>Antiscalant- where silica is up to 100 ppm/where Mica is up to 100 ppm - No</b>
	<b>Iron removing Filter max. 0.3 ppm - No</b>
	<b>Chloride &amp; Flouride removal Pump - No</b>
	<b>Availability of type test reporst(Design Evaluation Reports) as per cl. No.5.3,6.1,6.2.1,6.2.2.1,6.2.2.2,6.2.2.3,6.2.2.4 to IS:14724 and cl. 4,table 1,2,3and 4 to IS 10500. - Yes</b>
	<b>Test certificate No. - 123</b>
	<b>Test Report Date - 15/5/2017</b>
	<b>Name of lab where test conducted - Bluebird Pure Private Limited</b>
	<b>Address of the test Lab - Jahangirpuri, Delhi</b>
Additional Features (Buyer)	N/A

---Thank You---